



MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 3
VERSION DATE: 6/18/2024

DOCUMENT #: P-UM-0012
PAGE: 1 OF 18

PERC



Module Types
MSExxx-HTOB
MSExxx-HT2B





MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 3
VERSION DATE: 6/18/2024

DOCUMENT #: P-UM-0012
PAGE: 2 OF 18

1.0	DISCLAIMER	3
2.0	HANDLING AND USE	3
3.0	LIMITATION OF LIABILITY AND LIMITED REMEDIES	3
4.0	GENERAL INSTRUCTIONS	3
5.0	SAFETY	4
	5.1 General Warning-3	
	5.2 Mechanical-3	
	5.3 Electrical Shock Hazard-3	
	5.4 Fire-3	
6.0	OPERATING CONDITIONS	6
	6.1 Temperature -4	
	6.2 Installation Condition -4	
7.0	UNPACKING & STORAGE	7
	7.1 General Instruction-5	
	7.2 Unpacking Instructions-5	
8.0	PRODUCT SPECIFICATION	9
	Table 1: Electrical Ratings of MSE PERC 108 half-cell (Blacksheet) Modules Series	
	Table 2: Electrical Ratings of MSE PERC 120 half-cell (Black backsheet) Module Series	
	Table 3: Module Temperature Coefficient	
9.0	MECHANICAL INSTALLATION	10
	9.1 Ground Mount	
	9.2 Roof Mount	
	9.3 Pole Mount	
	9.4 Mounting Options	
	Table 4: Design load as specified by UL61730	
	Figure 1: Clamp Method	
	Figure 2: Bolt Method	
10.0	GROUNDING INSTRUCTIONS	15
	10.1 Weeb-UIR	
11.0	ELECTRICAL INSTALLATION	16
	11.1 Local/National Code and Local Regulation	
	11.2 Wiring	
	11.3 Connectors	
	11.4 Diodes	
12.0	MAINTENANCE	18
	12.1 Visual Inspection	
	12.2 Cleaning	



MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 3

VERSION DATE: 6/18/2024

DOCUMENT #: P-UM-0012

PAGE: 3 OF 18

1.0 DISCLAIMER

This manual is provided on an “as is” basis without warranty, covenant or representative of any kind, express or implied, including the warranties of merchantability or fitness for a particular purpose. Mission Solar Energy uses its best efforts to ensure the accuracy of the contents of this manual; however, Mission Solar Energy is not responsible for the accuracy of said contents or results of your use of the same. Under no circumstances will Mission Solar Energy be liable to you or any third party for damages arising under any legal theory including contract, tort, negligence or strict liability or for direct, indirect, special, consequential; or punitive damages of any kind, including lost profits. Mission Solar Energy reserves the right to make changes without further notice to this manual and to any modules. Mission Solar Energy does not convey any license under its intellectual property rights. Mission Solar Energy assumes no responsibility for any infringement to patents or other rights of third parties that may result from use of this manual or related module.

2.0 HANDLING AND USE

Mission Solar Energy shall not be liable for, and buyer shall indemnify, defend and hold harmless Mission Solar Energy, its affiliates and their respective officers, directors, employees, representatives and agents (“indemnities”) from and against, any and all claims, losses, liabilities, costs and expenses (including attorneys’ fees) (“claims”) arising out of or resulting from the handling, use, processing, alteration, distributions, sale or marketing of modules and this manual, or any other action or inaction with regard to the modules and this manual, in each case after the delivery thereof to buyer; provided however, that buyer shall not be liable to Mission Solar Energy for damages directly caused by the sole negligence of Mission Solar Energy. Buyer’s obligations under this section shall survive the termination, cancellations or expiration of all orders delivered under these terms and the cessation of any business transaction between Mission Solar Energy and buyer.

3.0 LIMITATION OF LIABILITY AND LIMITED REMEDIES

In no event will Mission Solar Energy be liable to buyer for any lost or prospective profits, indirect, incidental, consequential, special, exemplary or punitive damages, including, without limitation, lost earnings, or business interruption, whether or not based upon Mission Solar Energy’s negligence, breach of warranty, strict liability, in tort or any other cause of action. Buyer’s exclusive remedy VIS-À-VIS Mission Solar Energy or any other cause if action related to the modules and this manual is at Mission Solar Energy’s option limited to (i) replacement of the non-conforming modules; or (ii) refund to buyer of the portion of the purchase of the purchase price attributable to such non-conforming modules. In no event shall Mission Solar Energy’s cumulative liability exceed the price of modules sold which was the direct cause of the alleged loss, damage or injury.

4.0 GENERAL INSTRUCTIONS

This manual provides important safety instructions regarding installation, maintenance and handling of Mission Solar Energy photovoltaic modules. All the users should read this manual carefully and follow the instructions strictly. The installation of solar modules requires specialized skills and experience and should only be performed by licensed professionals. Failure to handle, install, operate, and maintain Mission Solar Energy photovoltaic modules as specified within this manual is hazardous and may invalidate any applicable product warranty terms.

MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 3
VERSION DATE: 6/18/2024

DOCUMENT #: P-UM-0012
PAGE: 4 OF 18

5.0 SAFETY

WARNING



5.1 GENERAL WARNING

You must understand and follow all applicable local, state and federal regulations in addition to standards for building construction, electrical design, fire and safety. Check with local authorities to determine applicable permitting requirements before attempting to install or maintain PV modules.

- Module interconnects pass direct current (DC) when exposed to sunlight or other light sources.
- Contact with electrically active parts of the module, such as terminals, can result in injury or death, whether the module is connected or disconnected.
- Never wear metallic rings, watch bands, ear, nose or lip rings or other metallic devices when installing or trouble shooting a photovoltaic system.
- Mission Solar PV modules are intended for use in terrestrial applications only with an altitude of less than 2000m, thus excluding aerospace or maritime conditions or use with sunlight concentration. Excluded applications include, but are not limited to, installations where modules are likely to come in contact with any salt water or where likely to become partially or wholly submerged in fresh or salt water. It is advised that modules be installed at least 500m away from the sea.

5.2 MECHANICAL

- Rooftop PV systems should only be installed on dwellings that have been formally analyzed for structural integrity, and confirmed to be capable of handling the additional weighted load of PV system components including PV modules by a certified building specialist or engineer. For your safety, do not attempt to work on a rooftop until safety precautions have been identified and taken, including without limitation fall protection measures, ladders or stairways, and personal protective equipment (PPE).
- For your safety, do not install or handle PV modules under adverse conditions, including and without limitation to strong or gusty winds and wet or frosted roof surfaces.
- The flat-plate PV module construction consists of a laminated assembly of solar cells encapsulated within an insulating material with a rigid glass surface and an insulated substrate. The laminated assembly is supported by an aluminum frame, which is also used for mounting the module.

5.3 ELECTRICAL SHOCK HAZARD

- PV modules can produce current and voltage when exposed to light of any intensity. Electrical current increases with higher light intensity.
- DC voltage of 30 Volts or higher is potentially lethal. Contacting the live circuitry of a PV system operating under light can result in lethal electric shock.
- Use insulated tools and do not wear metallic jewelry while working with PV modules.



MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 3

VERSION DATE: 6/18/2024

DOCUMENT #: P-UM-0012

PAGE: 5 OF 18

5.4 FIRE

- Mission Solar Energy modules hold PV Type 1 fire rating in accordance with the UL 61730 standard.
- The fire rating of this module is valid only when mounted in the manner specified in the mechanical mounting instructions. **See 9.0 Mechanical Installation** for details.
- PV modules are electricity generating devices that may affect the fire safety of a building.
- The use of improper installation methods and/or defective parts may result in the unexpected occurrence of an electrical arc during operation.
- The recommended standoff height is no less than 150mm (6 inches). If other mounting means are employed this may affect the fire class ratings. A minimum slope of 5 in/ft. for installation over a roof is required to maintain the Class C fire rating. Modules must be mounted over a fire-resistant roof covering rated for the application.
- In order to mitigate the risk of fire in this event, PV modules should not be installed near flammable liquids, gases and/or locations with hazardous materials.
- In the event of a fire, PV modules may continue to produce a dangerous voltage, even if they have been disconnected from the inverter, have been partly or entirely destroyed, or the system wiring has been compromised or destroyed.
- In the event of fire, inform the fire crew about the particular hazards from the PV system, and stay away from all elements of the PV system during and after a fire until the necessary steps have been taken to make the PV system safe.
- In order to avoid arcing and electrical shock, do not disconnect electrical connections under load.
- Faulty connections can also result in arcing and electrical shock.
- Keep connectors dry and clean; ensure that they are in proper working condition.
- Never insert metallic objects into the connectors, or modify them in any way in order to secure an electrical connection.
- Modules must be handled with care. If the front glass is broken or if the polymer back-skin is torn, avoid unprotected contact with any module surface or the frame as it can produce electrical shock, particularly when the module is wet.
- Do not touch or handle PV modules with broken glass, separated frames or a damaged back sheet unless the PV modules are first disconnected and you are wearing proper PPE.
- Broken or damaged modules must be disposed of properly.
- Avoid handling PV modules when they are wet unless cleaning the PV modules as directed in this manual. **See 12.2 Cleaning for details.**
- Never touch electronic connections that are wet without protecting yourself with insulated gloves. Artificially concentrated light should not be directed on the module or panel.

MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 3
VERSION DATE: 6/18/2024

DOCUMENT #: P-UM-0012
PAGE: 6 OF 18

6.0 OPERATING CONDITIONS

6.1 TEMPERATURE

All the modules must be mounted in environments that ensure they operate within the following minimum and maximum ambient air temperatures:

- **Minimum ambient air temperatures:** -40°C (-40°F)
- **Maximum ambient air temperatures:** +40°C (104°F)

6.2 INSTALLATION CONDITION

Orient the module correctly. Mount the modules with the junction box in the uppermost position and hang the wires downwards to avoid the ingress of water. For optimal module performance install PV modules facing true south in northern latitudes and true north in southern latitudes. Shading will reduce electrical production and can prematurely degrade the viability of the solar module. This installation is applicable when the module is in portrait orientation. The modules have been evaluated by UL standards for mounting using the recommended mounting positions.



















MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 3
VERSION DATE: 6/18/2024

DOCUMENT #: P-UM-0012
PAGE: 7 OF 18

7.0 UNPACKING & STORAGE

7.1 GENERAL INSTRUCTIONS

	Store modules in an environment consistent with prudent solar industry practices, including storage in dry conditions such that modules (or any part thereof) are not immersed in water.		Do not carry the module above the head.
	Do not allow children or unauthorized persons near the installation site or storage area of modules.		Do not drop or place objects such as tools on the modules.
	Do not use forklift with less than 72-inch forks to handle module pallet.		Do not mark the modules with sharp instruments.
	Unpack the module pallet with care and follow the unpacking steps in this manual. Be careful when unpacking, transporting and storing the modules		Particular attention should be taken to avoid module back sheet contact with sharp objects. Scratches may directly affect product safety.
	Do not carry a module by its wires or junction box. At least two or more people are recommended to carry the module for safe handling.		Do not leave a module unsupported or unsecured.
	Do not place modules directly on top of each other and prevent modules from touching one another.		Do not change the wiring of any bypass diodes.
	Do not place excessive loads on the module or twist the module frame.		Keep all electrical contacts clean and dry.
	Do not stand, step, walk and/or jump on any part of the module.		Modules may have sharp frame corners. Use of puncture and cut-resistant gloves is recommended.

MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 3
VERSION DATE: 6/18/2024

DOCUMENT #: P-UM-0012
PAGE: 8 OF 18


		
<p>Prior to unpacking, ensure pallets is set on a level surface and proper PPE is equipped by all personnel. Proper PPE for unpacking includes but is not limited to eye protection, cut resistant gloves and steel-toe foot wear</p>	<p>Cut the four green strips of banding material with scissors. These strips are under high tension and will snap when cut. Eye protection is highly recommended.</p>	<p>Lift the pallet lid and set it away from the unpacking area.</p>
		
<p>Remove white corner protectors.</p>	<p>The first module must be separated and pulled out with additional care so as to not scratch the modules. Continue removing modules by peeling back the tape, pulling the module upward. Remove the four corner clips prior to installation</p>	

MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 3
VERSION DATE: 6/18/2024

DOCUMENT #: P-UM-0012
PAGE: 9 OF 18

8.0 PRODUCTION SPECIFICATION



Mission Solar PV Modules have been certified to UL61730 for a minimum 1600 Pa of design load on back and front of the module.

The performance of solar modules is defined on the standard test conditions (STC). These conditions define performance at an incident of 1000 W/m², a module temperature of 25 ± 2°C and AM of 1.5 (AM = Air Mass) as per IEC60904-3. The air mass determines the radiation impact and the spectral combination of the light arriving on the earth's surface.

TABLE 1: ELECTRICAL RATINGS OF MSE PERC 108HALF-CELL (BLACK BACKSHEET) MODULE SERIES

Parameters			MSE390HT0B	MSE395HT0B	MSE400HT0B	MSE405HT0B	MSE410HT0B
Power Output	P _{max}	Wp	390	395	400	405	410
	Tolerance	%	-0/+3	-0/+3	-0/+3	-0/+3	-0/+3
Open Circuit Voltage	V _{oc}	V	36.78	36.94	37.09	37.27	37.41
Short-Circuit Current	I _{sc}	A	13.59	13.67	13.75	13.82	13.90
Rated Voltage	V _{mp}	V	30.57	30.77	30.96	31.16	31.38
Rated Current	I _{mp}	A	12.76	12.84	12.92	13.00	13.07
Fuse rating		A	25	25	25	25	25
Max. System Voltage		V	1,000	1,000	1,000	1,000	1,000

TABLE 2: ELECTRICAL RATINGS OF MSE PERC 120HALF-CELL (BLACK BACKSHEET) MODULE SERIES

Parameters			MSE440HT2B	MSE445HT2B	MSE450HT2B	MSE455HT2B	MSE460HT2B
Power Output	P _{max}	Wp	440	445	450	455	460
	Tolerance	%	-0/+3	-0/+3	-0/+3	-0/+3	-0/+3
Open Circuit Voltage	V _{oc}	V	41.01	41.15	41.29	41.47	41.64
Short-Circuit Current	I _{sc}	A	13.69	13.75	13.82	13.89	13.97
Rated Voltage	V _{mp}	V	33.91	34.06	34.21	34.38	34.55
Rated Current	I _{mp}	A	12.98	13.07	13.16	13.23	13.31
Fuse rating		A	25	25	25	25	25
Max. System Voltage		V	1,000	1,000	1,000	1,000	1,000



MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 3
VERSION DATE: 6/18/2024

DOCUMENT #: P-UM-0012
PAGE: 10 OF 18

TABLE 3: MODULE TEMPERATURE COEFFICIENT

Module	Peak power: δ (%/°C)	Voltage: B (%/°C)	Current: α (%/°C)	NOCT (°C)
MSExxxHT0B <i>(xxx=440-460, in step of 5W, xxx is standing for rated output power at STC)</i>	-0.331% / °C	-0.251% / °C	0.029% / °C	45.52 °C
MSExxxHT2B <i>(xxx=440-460, in step of 5W, xxx is standing for rated output power at STC)</i>	-0.326% / °C	-0.250% / °C	0.038% / °C	45.52 °C

9.0 MECHANICAL INSTALLATION

Mission Solar PV modules are considered to be in compliance with UL 61730 only when mounted in the manner specified by the mounting options below. Per UL standards, the maximum number of modules connected in series/parallel with correction factor of 1.56 as specified in the NEC is as follows:

- a. **21/1** for 108 half-cell modules with maximum system voltage of 1000V
- b. **19/1** for 120 half-cell modules with maximum system voltage of 1000V

- Please refer to your local Authority Having Jurisdiction (AHJ) as well as best installation practices for the maximum number of modules that can be installed in series and in parallel for your specific installation project site and application.
- For proper guidelines on tilt or elevation angle for your installation, please refer to the standard PV installation guide from a reputable installer or systems integrator.
- Always follow the instructions and safety precautions from the installation guide that came with the support frame to be used.
- Drilling holes on the module's frame and glass parts is not recommended as it will void the warranty.
- If additional wind or snow loads are anticipated for this installation, the support module mounting structure must be made of durable corrosion-resistant and UV-resistant material.
- Modules should not be installed near any other equipment.
- Ensure that the module is laid evenly between the two rails and sits perpendicular on the railing. If the module is not perpendicular, slightly adjust the clamp positions to get the proper alignment.
- Modules must be secured to the mounting structure using all four mounting points for normal installation.

9.1 GROUND MOUNT

Select a mounting system with enough height to prevent the lowest edge of the module from being covered with snow during winter in areas that experience heavy snowfalls. In addition, ensure that the lowest portion of the module is placed high enough so that it does not get covered in debris from plants or trees or damaged by sand and stone driven by wind.

MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 3

VERSION DATE: 6/18/2024

DOCUMENT #: P-UM-0012

PAGE: 11 OF 18

9.2 ROOF MOUNT

When installing module on a roof or building, ensure that it is securely fastened and cannot fall as a result of wind or snow loads. Provide adequate ventilation under the module for cooling, 10 cm (3 15/16 in) minimum air space between the module and the mounting surface. The slope should be less than 5 in/ft. in order to maintain the certified fire class rating. When installing module on a roof, ensure that the roof construction is suitable. In addition, any roof penetration required to mount the module must be properly sealed to prevent leaks. In some cases, a special support frame maybe necessary.



- ❖ The roof installation of solar modules may affect the fireproofing of the house construction. The fire rating of this module is valid only when mounted in them manner specified in the mechanical mounting instructions. The modules have PV Type 1 of fire rating in accordance with the UL61730. Installing a module during strong winds may cause accidents.

9.3 POLE MOUNT

When installing module on a pole, choose a pole & module mounting structure that will withstand anticipated wind and snow loads for the area.

9.4 MOUNTING OPTIONS

9.4.1 Clamp method

The capture area of the clamps should be a minimum 9.2 mm x 38 mm (3/8 in x 1 1/2 in). Clamps are used in combination with a flat washer, locking washer, 1/4" nut and bolt that shall be torqued to 16±2 N-m (11.8 ± 1.5 lbf.ft). Four clamps are secured on the long side frame. The clamp placement locations are measured from the middle of the clamp to the short side frame.

9.4.2 Bolt method

Modules are secured to the support structure using an M7 x 16 mm (or 1/4" x 3/4") bolt and nut with flat washer and spring washer. Hardware is used on all four of the mounting holes on the long side frame, two on each side. Bolt shall be torqued to 16±2 N-m (11.8 ± 1.5 lbf.ft).

MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 3
VERSION DATE: 6/18/2024


DOCUMENT #: P-UM-0012
PAGE: 12 OF 18

TABLE 4: DESIGN LOAD AS SPECIFIED BY UL61730

INSTALLATION TYPE	MODULE	*MOUNTING DISTANCE [D]	FRONT OF MODULE DESIGN LOAD	BACK OF MODULE DESIGN LOAD
Clamp method	HT0B	$19\text{ mm} \leq D < 336\text{ mm}$	1600 Pa	1600 Pa
		$D = 336\text{ mm}$	1600 Pa	3600 Pa
		$336\text{ mm} < D < 387\text{ mm}$	1600 Pa	1600 Pa
		$D = 387\text{ mm}$	3600 Pa	1600 Pa
	HT2B	$D = 429\text{ mm}$	3600 Pa	1600 Pa
Bolt method	HT0B	$D = 387\text{ mm}$	1600 Pa	1600 Pa
	HT2B	$D = 429\text{ mm}$	1600 Pa	1600 Pa

**Mounting Distance [D] – distance between edge of module and middle of clamp (or mounting hole) location. This is assuming that modules are mounted on a certified mounting system*

FIGURE 1: CLAMP METHOD



Note: Allowable clamp minimum dimensions are as follows:

DIMENSION	mm	in
A	9	0.35
B	38	1.5

MODULE INSTALLATION USER MANUAL FOR PERC SERIES


VERSION: 2

VERSION DATE: 4/23/2024

DOCUMENT #: P-UM-0012

PAGE: 13 OF 18

FIGURE 2: BOLT METHOD



- The recommended standoff height is 150 mm (5 7/8in). If other mounting means are employed this may affect the UL Listing or the fire class ratings.
- Minimum slope of 5 in/ft for installation over a roof is required to maintain the fire class ratings.
- The PV modules are designed for a maximum altitude of 2000m.
- Artificially concentrated sunlight should not be directed on the module.
- Rated electrical characteristics are within 10 percent of measured values at Standard Test Conditions of: 1000 W/m², 25°C cell temperature and solar spectral irradiance as per IEC 60904-3
- Under normal conditions, a photovoltaic module may experience conditions that produce more current and/or voltage than reported at Standard Test Conditions. Accordingly, the values of I_{sc} should be multiplied by a factor of 1.25 and V_{oc} by a factor of up to 1.25 when determining component voltage ratings, conductor capacities, fuse sizes and size of controls connected to the module output.
- Refer to Section 690-8 of the National Electric Code for an additional multiplying factor of 1.25 which may be applicable.

MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 2


DOCUMENT #: P-UM-0012

VERSION DATE: 4/23/2024

PAGE: 14 OF 18


MSE PERC 108 HALF-CELL

1) HT0B SERIES [Units: MM/IN]



MSE PERC 120 HALF-CELL

2) HT2B SERIES [Units: MM/IN]



MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 2

DOCUMENT #: P-UM-0012

VERSION DATE: 4/23/2024

PAGE: 15 OF 18

10.0 GROUNDING INSTRUCTIONS

A module with exposed conductive parts is considered to be in compliance with UL 61730 only when it is electrically grounded in accordance with the instructions presented below and the requirements of the National Electric Code. To reduce the possibility of electrical shock, ground the frame of the module or array before wiring the circuit using a grounding method that meets NEC requirements for grounding solar electrical systems. In order to install on anodized aluminum frames, Mission Solar Energy modules shall be grounded using grounding hardware that has been certified to meet requirements for grounding systems in UL467, UL61730 or UL1741, which Mission Solar Energy recommends one of the following methods of grounding the module frame. The attachment must be made in conformance with the grounding device manufacturer's instructions and be used with a racking system in compliance with UL Outline (Standard) 2703 where this module has been evaluated with that racking system.


10.1 WEEBUIR

The WEEB washer family of products can be used to bond anodized aluminum, galvanized steel, steel and other electrically conductive metal structures. All installations shall be in accordance with NEC requirements in the USA and with CSA C22.1 in Canada. The WEEB washers are for use with modules that have a maximum fuse rating of less than 25A. Use WEEB-UIR to bond solar modules to module mounting purlin and torque fasteners to 7 ft-lb / 9.5 N-m using Penetrox-A on threads.

The following UL Recognized Bonding Washer, manufactured by BURNDY LLC (E351343), should be used to provide a reliable grounding connection to the module frame.

MODULE	GROUNDING DEV		
	Manufacturer	Type	Torque rating
All	BURNDY LLC	WEEB-UIR grounding washer)	9.5

The BURNDY grounding washer should be used in combination with a flat washer and M5 size nut/bolt to bond the module frame to the mounting rails/support (see figure 3).



Grounding should be achieved through securement to the array frame. The array frame shall be grounded in accordance with NEC article 250, and CSA C22.1, Safety standard for electrical installations, Canadian Electrical Code, Part 1, for cUL listed modules.

11.0 ELECTRICAL INSTALLATION

11.1 LOCAL/NATIONAL CODE AND LOCAL REGULATION



To carry out installation, local regulations that may apply should be considered such as NEC (USA) OR Canadian Electrical Code. Wiring should be performed by a qualified and licensed professional. Wiring should be protected to help ensure personal safety and to prevent damage. All modules connected in series should be of same model number and/or same type. Do not connect modules in parallel without using a combiner box or equivalent.

Under normal conditions, a photovoltaic module is likely to experience conditions that produce current and/or voltage other than reported at Standard Test Conditions. The requirements of the National Electric Code (NEC) in Article 690 shall be followed to address these increased outputs. In installations not under the requirements of the NEC, the values of ISC and VOC marked on this module should be multiplied by a factor of 1.25 when determining component voltage ratings, conductor capacities, over current device ratings and the size of controls connected to the PV output.

11.2 WIRING

Mission Solar PV modules come with a factory assembled junction box. Do not open the junction box in any case. Wiring must be done in accordance with local/national code and regulations; wear protective gloves and shoes to avoid electric shock. Address the following recommendations:

- The modules combined in parallel will produce a specific current output. Each series string or module is required to be fused. Table 1 describes the maximum fuse size allowed.
- Do not connect the modules if the connectors are wet.
- Be sure to put the cables away from sharp edges.
- If you need additional cables you must use exclusively solar cable of 12AWG/4mm² minimum cross-sections, with ability to work in a temperature range of at least -40°C and 90°C.
- Install the modules so that water from rain or condensation cannot penetrate inside the cable conduits.
- Fix cables to the structure so that the connectors are protected from water ingress. Cables should be held by UV resistant clamps or ties.
- To minimize possible effects of lightning induced voltages, the surface of all conductive loops must be as small as possible.
- Check that the wiring is correct before starting the installation by verifying that the open voltage is within expected values.
- Protect cables that could suffer mechanical damage.
- Avoid direct sunlight on cables.
- Maximum series fuse rating is 25A.

MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 2

DOCUMENT #: P-UM-0012

VERSION DATE: 4/23/2024

PAGE: 17 OF 18

- Details for wiring must be in accordance with the NEC
- The grounding method for the frame of arrays shall comply with the NEC, Article 250.
- Installation shall be in accordance with CSA C22.1, Safety Standard for Electrical Installations, Canadian Electrical Code and Part 1.
- Modules may be connected in series (voltage additive) and/or in parallel (current additive) to produce the appropriate electrical output. When connecting modules in parallel, each module (or series string of modules so connected) shall be connected according to the maximum series fuse as specified.
- Recommended series connection of module open circuit voltage should not exceed 80% limits range of the system voltage and the fuse should be connected at the end of each array.
- The installation instructions specify that grounding is achieved through securement to the array frame. The array frame must be grounded in accordance with NEC Article 250.
- Mission Solar modules are equipped with factory installed wires and connectors. These modules have been designed to be easily connected in series. Each module has two single-conductor wires, one positive and one negative, that are pre-wired inside the junction box.
- The connectors at the opposite end of these wires allow easy series connection of adjacent modules by firmly inserting the male connector of a module into the female connector of an adjacent module until the connector is fully seated.
- A separate return wire or wires are required to run the positive and negative terminations of the series string of modules to load. Male and female connectors pre-attached to wires could be used at the string terminations for return wire connections or for source circuit box terminations.

11.3 CONNECTORS

- Keep connectors dry and clean. Ensure that connector caps are hand-tight before connecting the modules.
- Do not attempt to make an electrical connection with wet, soiled, or otherwise faulty connectors.
- Avoid sunlight exposure and water immersion of the connectors. Avoid allowing connectors to rest on the ground.
- Ensure cable connectors are UL and Canadian code complaint.
- Faulty connections can result in arcs and electrical shock.
- Check that all electrical connections are securely fastened.
- Make sure that all locking connectors are fully engaged and locked.

MANUFACTURER	CONNECTOR MODEL NAME	ALLOWABLE MATING CONNECTOR MODEL NAME
Staubli Electrical Connectors AG www.staubli.com	PV-KBT4/6II-UR	PV-KST4/6II-UR

PV-KBT4



PV-KST4





MODULE INSTALLATION USER MANUAL FOR PERC SERIES

VERSION: 2

DOCUMENT #: P-UM-0012

VERSION DATE: 4/23/2024

PAGE: 18 OF 18

11.4 DIODES

- The junction boxes used with Mission Solar Energy modules contain bypass diodes wired in parallel with the PV cell strings.
- In the case of partial shading, the diodes bypass the current generated by the non-shaded cells, thereby limiting modules heating and performance losses. Bypass diodes are not over current protection devices.
- Bypass diodes divert current from the cell strings in the event of partial shading. In the event of a known or suspected diode failure, installers or maintenance providers should contact Mission Solar Energy.
- Never attempt to open the junction box.

12.0 MAINTENANCE

12.1 VISUAL INSPECTION

Mission Solar Energy recommends that PV systems be periodically inspected by the installer or other qualified personnel. The purpose of the PV system inspection is to ensure that all system components are functioning properly. At a minimum, this inspection should confirm the following:

- All cables and connector attachments are undamaged and properly secured.
- No sharp objects are in contact with the PV module surfaces.
- PV modules are not shaded by unwanted obstacles and/or foreign material.
- Mounting and grounding components are tightly secured with no corrosion.
- Glass is intact, without cracks or shatters.
- Defects should be addressed immediately.

12.2 CLEANING

- The dust accumulated on the front transparent substrate may reduce the power output, and may even cause regional hot-spot effect.
- It's usually not dangerous for the accumulated dust to reduce the sunshine because the light intensity is still homogeneous and power reduction is not usually obvious.
- When modules are installed, avoid environmental influence factors that cast shadows and cover part or all of the modules. This includes other modules, system support, bird droppings, dust, pollen and so on. This debris may distinctly reduce the power output.
- The cleaning frequency depends on the accumulation frequency and can vary from 6 months to 2 years. Do not use alkaline, abrasive, alkali or acid materials, detergents, or cleaning solutions to clean the module.
- It is recommended to wipe the glass surface with a wet sponge or soft cloth. Please do not clean the glass with a cleaning agent which contains acid or alkali.